

U.S. Department of Energy - Energy Efficiency and Renewable Energy

A Consumer's Guide to Energy Efficiency and Renewable Energy

Radiant Heating

Radiant heating systems involve supplying heat directly to the floor or to panels in the wall or ceiling of a house. The systems depend largely on radiant heat transfer: the delivery of heat directly from the hot surface to the people and objects in the room via the radiation of heat, which is also called infrared radiation. Radiant heating is the effect you feel when you can feel the warmth of a hot stovetop element from across the room. When radiant heating is located in the floor, it is often called radiant floor heating or simply floor heating.

Radiant heating has a number of advantages: it is more efficient than baseboard heating and usually more efficient than forced-air heating because no energy is lost through ducts. The lack of moving air can also be advantageous to people with severe allergies. Hydronic (liquid-based) systems use little electricity, a benefit for homes off the power grid or in areas with high electricity prices. The hydronic systems can also be heated with a wide variety of energy sources, including standard gas- or oil-fired boilers, wood-fired boilers, solar water heaters, or some combination of these heat sources.

Despite their name, radiant floor heating systems also depend heavily on convection, the natural circulation of heat within a room, caused by heat rising from the floor. Radiant floor heating systems are significantly different than the radiant panels used in walls and ceilings. For this reason, the following sections discuss radiant floor heat and radiant panels separately.

Radiant Floor Heat

There are three types of radiant floor heat: radiant air floors (air is the heat-carrying medium); electric radiant floors; and hot water (hydronic) radiant floors. All three types can be further subdivided by the type of installation: those that make use of the large thermal mass of a concrete slab floor or lightweight concrete over a wooden subfloor (these are called "wet installations"); and those in which the installer "sandwiches" the radiant floor tubing between two layers of plywood or attaches the tubing under the finished floor or subfloor ("dry installations").

Types of Radiant Floor Heat

Air-Heated Radiant Floors

Because air cannot hold large amounts of heat, radiant air floors are not cost-effective in residential applications, and are seldom installed. Although they can be combined with solar air heating systems, those systems suffer from the obvious drawback of only being available in the daytime, when heating loads are generally lower. Because of the inefficiency of trying to heat a home with a conventional furnace by pumping air through the floors, the benefits of using solar heat during the day are outweighed by the disadvantages of using the conventional system at night. Although some early solar air heating systems used rocks as a heat-storage medium, this approach is not recommended. For further information, see the section on [solar air heating systems](#).

Electric Radiant Floors

Electric radiant floors typically consist of electric cables built into the floor. Systems that feature mats of electrically conductive plastic are also available, and are mounted onto the subfloor below a floor covering such as tile.

Because of the relatively high cost of electricity, electric radiant floors are usually only

cost-effective if they include a significant thermal mass, such as a thick concrete floor, and your electric utility company offers time-of-use rates. Time-of-use rates allow you to "charge" the concrete floor with heat during off-peak hours (approximately 9 p.m. to 6 a.m.). If the floor's thermal mass is large enough, the heat stored in it will keep the house comfortable for eight to ten hours, without any further electrical input (particularly when daytime temperatures are significantly warmer than nighttime temperatures). This saves a considerable number of energy dollars compared to heating at peak electric rates during the day.

Electric radiant floors may also make sense for additions onto homes for which it would be impractical to extend the heating system into the addition. However, homeowners should examine other options, such as [mini-split heat pumps](#), which operate more efficiently and have the advantage of also providing cooling.

Hydronic Radiant Floors

Hydronic (liquid) systems are the most popular and cost-effective radiant heating systems for heating-dominated climates. Hydronic radiant floor systems pump heated water from a boiler through tubing laid in a pattern underneath the floor. In some systems, the temperature in each room is controlled by regulating the flow of hot water through each tubing loop. This is done by a system of zoning valves or pumps and thermostats. The cost of installing a hydronic radiant floor varies by location and also depends on the size of the home, the type of installation, the floor covering, remoteness of the site, and the cost of labor.

Types of Floor Installations

Whether cables or tubing, the methods of installing electric and hydronic radiant systems in floors is about the same.

So-called "wet" installations embed the cables or tubing within a solid floor and are the oldest form of modern radiant floor systems. The tubing or cable can be embedded in a thick concrete foundation slab (commonly used in "slab" ranch houses that don't have basements) or in a thin layer of concrete, gypsum, or other material installed on top of a subfloor. If concrete is used and the new floor is not on solid earth, additional floor support may be necessary because of the added weight. You should consult a professional engineer to determine the floor's carrying capacity.

Thick concrete slab systems have high heat capacity and are ideal for storing heat from solar energy systems, which have a fluctuating heat output. The downside of the thick slabs is their slow thermal response time, which makes strategies such as night or daytime setbacks difficult if not impossible. Most experts recommend maintaining a constant temperature in homes with these heating systems.

Due to recent innovations in floor technology, so-called "dry" floors, in which the cables or tubing run in an air space beneath the floor, have been gaining in popularity, mainly because a dry floor is faster and less expensive to build. But because dry floors involve heating an air space, the radiant heating system needs to operate at a higher temperature.

Some dry installations involve suspending the tubing or cables underneath the subfloor between the joists. This method usually requires drilling through the floor joists in order to install the tubing. Reflective insulation must also be installed under the tubes to direct the heat upward. Tubing or cables may also be installed from above the floor, between two layers of subfloor. In these instances, liquid tubing is often fitted into aluminum diffusers that spread the water's heat across the floor in order to heat the floor more evenly. The tubing and heat diffusers are secured between furring strips

(sleepers), which carry the weight of the new subfloor and finished floor surface.

At least one company has improved on this idea by making a plywood subfloor material manufactured with tubing grooves and aluminum heat diffuser plates built into them. The manufacturer claims that this product makes a radiant floor system (for new construction) considerably less expensive to install and faster to react to room temperature changes. Such products also allow for the use of half as much tubing or cabling since the heat transfer of the floor is greatly improved over more traditional dry or wet floors.

Floor Coverings

Ceramic tile is the most common and effective floor covering for radiant floor heating, as it conducts heat well from the floor and adds thermal storage because of its high heat capacity. Common floor coverings like vinyl and linoleum sheet goods, carpeting, or wood can also be used, but any covering that helps to insulate the floor from the room will decrease the efficiency of the system.

If you want carpeting, use a thin carpet with dense padding and install as little carpeting as possible. If some rooms, but not all, will have a floor covering, then those rooms should have a separate tubing loop to make the system heat these spaces more efficiently. This is because the water flowing under the covered floor will need to be hotter to compensate for the floor covering. Wood flooring should be laminated wood flooring instead of solid wood. This reduces the possibility of the wood shrinking and cracking from the drying effects of the heat.

Radiant Panels

Wall- and ceiling-mounted radiant panels are usually made of aluminum and can be heated with either electricity or with tubing that carries hot water, although the latter creates concerns about leakage in wall- or ceiling-mounted systems. The majority of commercially available radiant panels for homes are electrically heated.

Like any type of electric heat, radiant panels can be expensive to operate, but they can provide supplemental heating in some rooms or can provide heat to a home addition when extending the conventional heating system is impractical.

Unlike other types of radiant heating systems, radiant panels have very low heat capacity and have the quickest response time of any heating technology. Because the panels can be individually controlled for each room, the quick response feature can potentially result in cost and energy savings compared to other systems when rooms are infrequently occupied: when entering a room, the occupant can increase the temperature setting and reach a comfortable level within minutes. But as with any system, the thermostat must be maintained at a minimum temperature that will prevent pipes from freezing.

Radiant heating panels operate on a line-of-site basis: you'll be most comfortable if you're close to the panel. Some people find the ceiling-mounted systems uncomfortable, since the panels heat the top of their heads and shoulders more effectively than the rest of their body.

Learn More

Related Links

- [Radiant Panel Association](#)
- [Radiant Floor Heating - Dry System Hydronic](#)
Partnership for Advanced Technology in Housing
- [Electric Radiant Ceiling Panels](#)

Partnership for Advanced Technology in Housing

Reading List

- Hall, J. (14 October 2002). "Mini-Duct Systems Complement Radiant Heat." [Air Conditioning, Heating, & Refrigeration News](#) p. 10.
- Baskin, E. (31 March 2003; Revised 30 September 2003). "Residential Radiant Cooling and Heating Assessment." ([PDF 3.4 MB](#)). Oak Ridge National Laboratory.
- Siegenthaler, J. (1995). *Modern Hydronic Heating*. Delmar Publishers.
- Holohan, H. (1995). *How Come?: Hydronic Heating Questions We've Been Asking For More Than 100 Years (With Straight Answers)*. Dan Holohan Associates, Inc.
- Holohan, D. (1998). *Hydronic Radiant Heating: A Practical Guide for the Nonengineer Installer*. 214 pp.
- [Final Report for Field Evaluation of PATH Technologies: Habitat For Humanity Home](#). (August 2003). Schenectady, New York: National Association of Home Builders.
- Siegenthaler, J. (2003). *Modern Hydronic Heating for Residential and Light Commercial Buildings, 2E*. Delmar Publishers. 512 pp.
- Holohan, D. (1995). *Pumping Away (And Other Really Cool Piping Options for Hydronic Systems)*. Dan Holohan Associates, Inc.
- Truini, J. (February 1995). "Adding Radiant-Floor Heating," *Home Mechanix* (91:792); pp. 56-61.
- "Another Setback for Radiant Floor Advocates?" (8 December 2002). [Energy Design Update](#) (22:12); p. 8.
- Nisson, N. (May 1997). "Can Radiant Floor Cooling Succeed Despite Design Limitation?" [Energy Design Update](#) (17:5); pp. 5-8.
- "Canadian Study Details the Impact of Carpets on Radiant Floor Heating." (November 1998). [Energy Design Update](#) (18:11); pp. 12-13.
- Kaercher, Jr., B. (June/July 1992). "Electric-Radiant Floors." *Fine Homebuilding* (No. 75); pp. 68-72.
- "Foil-Faced Bubble Pack Under Slabs." (September 2003). [Energy Design Update](#) (23:9); pp. 8-12.
- "Heat at Your Feet." (November 1993). *Home Mechanix* (89:780).
- Siegenthaler, J. (August 1993). "Hydronic Radiant Heat for Wood-Framed Floors." *The Journal of Light Construction* (11:11); pp. 34-37.
- Groff, R. (January 1994). "Mixing Forced-Air and Boiler Heat." *Fine Home Building* (No. 85); pp. 86-87.
- "No Setpoint Savings Found for In-Floor Radiant." (May 2001). [Energy Design Update](#) (21:5).
- Wilson, A. (January 2002). "Radiant-Floor Heating: When It Does—And Doesn't—Make Sense." *Environmental Building News* (11:1); pp. 1, 9-14.
- "Radiant-Floor Study Sparks Controversy." (February 2003). *Journal of Light Construction* (21:5); pp. 21, 26.
- Wardell, C. (September/October 1995). "Radiant Floor Systems." *Custom Builder* (10:6); pp. 26-30.
- Siegenthaler, J. (August 1992). "Radiant Slab Techniques." [The Journal of Light Construction](#) (10:11); pp. 21-24.
- Siegenthaler, J. (July 1995). "Radiant Slab on a Tight Budget," *The Journal of Light Construction* (13:10); pp. 47-50.
- Boucher, J. (April 2000). "Radiant Subfloor Panels." *Journal of Light Construction* (18:7); pp. 75-81.
- "Wet or Dry System? Here's How They Compare." (25 September 1995). *Air Conditioning, Heating & Refrigeration News* (196:4); p. 22.
- "Wood Floors and Radiant Heating." (January 2002). *Solplan Review* (No. 102);

pp. 3-5.

- "Installation Guide for Radiant Underfloor Heating." Hydronic Institute, available from the [Canadian Hydronics Council](#).
- Smith, S. (1 April 2004). "Electric: The Other Radiant Heat." *Plumbing and Mechanical*.
- D'Agnesse, J. (October 2006) "[Radiant Floor Heating](#)." *This Old House*.
- Klein, M.; McKneight, J.; Reser, R.; Shantz, D. (October/November 1995). "Gimme Shelter: Solar Hydronic Space Heating." *Home Power* (No. 49); pp. 43-47.
- Johnson, W. (September/October 1984). "Hybrid Solar System Supplies Radiant Heat." *Solar Engineering and Construction* (3:5); pp. 27-29.
- Hyatt, R. (October/November 2000). "Hydronic Heating on Renewable Energy." *Home Power* (No. 79); pp. 36-42.
- Friedlander, M. (April 1986). "Premium Heating with Radiant Slabs." *Solar Age* (11:4); pp. 66-71.
- Wilson, A. (January 1986). "Solar Energy and Radiant Floors." *New England Builder* (4:4); p. 15.
- Spaulding, S. "Solar Shines Again." *Radiant Living*. pp. 45-48 & 50.
- "[Hydronic Radiant Heating and Cooling](#)." (March 2004). Lawrence Berkeley National Laboratory.
- "[Electric Radiant Heat: Making the Right Choice](#)." (December 1996). *Energy Source Builder* (#48). Posted on Oikos Green Building Source.
- "[Radiant Floors Demand Careful Planning](#)." (June 1996). *Energy Source Builder* (#45). Posted on Oikos Green Building Source.
- "[Underfloor Installation Offers a Retrofit Solution](#)." (June 1996). *Energy Source Builder*. (#45). Posted on Oikos Green Building Source.
- "[Radiant Floors Create More Comfort, Use Less Energy](#)." (February 1996). *Energy Source Builder* (#43). Posted on Oikos Green Building Source.
- "[Research Supports Benefits of Radiant Ceiling Panels](#)." (February 1995). *Energy Source Builder* (#37). Posted on Oikos Green Building Source.

[Consumer's Guide Home](#) | [EERE Home](#) | [U.S. Department of Energy Webmaster](#) | [Web Site Policies](#) | [Security & Privacy](#) | [USA.gov](#)

Content Last Updated: September 12, 2005